

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7135-0328:158 Page 1 of 1

CATEGORY: Audible Signal Device

LISTEE: Potter, 2081 Craig Road, St. Louis, MO 63146
Contact: Brad Serangeli (314) 878-4321

DESIGN: Models MH-24TR and MH-24TW horns. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 10-28 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical and audibility ratings and UL label.

APPROVAL: Listed as horns for use with separately listed compatible fire alarm control units.

If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition is required, the appliances must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to listee's Installation Instructions Manual for details.

XLF: 7135-0587:107

03-13-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 20, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager